

GSTIN : 06AISP1195J1ZT

**HFEW**

# HARI FIRE & ENGG. WORKS

Mfrs. Of:- FIRE FIGHTING EQUIPMENTS

Main Bazar, Thanesar, Kurukshetra-136118

Ph.: 98121-81920



**TEST CERTIFICATE**

Valid For One Year Only

S. No.. HFEW-0212260

Dated.. 15-02-2021

1. This is to certify that the under noted chemicals Fire Extinguishers have this day been subject to Hydraulic Pressure Test of 250 lbs. Per square inch for two and half minutes with following results.

2. Type D.C.P. Co2 Wo2 ABC AFFF No. of Extinguishers SIXTEEN  
16

3. Individual numbers of Extinguishers which withstand the required test. N.A.

4. Individual number of Extinguishers which failed to withstand the required test and there for condemned as being unfit to further use. N.A.

Re- Filled on : 15-02-2021

5. REMARKS

Due on : 14-02-2022

6. M/s. PRINCIPAL, WELL WHISHER PUBLIC SCHOOL  
BODHNI, PEHOWA

For HARI FIRE & ENGG. WORKS



Auth. Signatory [Signature]

NOTE: SALE & SERVICE ALL OVER INDIA